

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7270-1209:193 Page 1 of 1

**CATEGORY:** Heat Detector

**LISTEE:** System Sensor, 3825 Ohio Avenue, St. Charles, IL 60174  
Contact: \*Trish Linhart (630) 377-6674 Fax (630) 377-7245

**DESIGN:** Models 5251P, 5251B and 5251H (fixed temperature) and 5251RP and 5251RB (fixed temperature with Rate-of-Rise) electronic heat detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 5215P, 5215RP, \*5251B and \*5251RB 135° F fixed temperature  
5251H 190° F fixed temperature

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical ratings, and UL Inc. Label

**APPROVAL:** Listed as heat detectors for use with Model B501 or B210LP base (CSFM Listing No. 7300-1209:128) and separately listed compatible fire alarm control units.

\*Rev. 06-16-2003 JEW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy**  
**Program Manager**